

Recommended Advisory Clauses

- (a) To note the comments of Chief Town Planner/Urban Design and Landscape, Planning Department:

Boundary Treatment (Drawing No. ST49/D2/EX/L/AS-400)

- (i) it is suggested that minimum 300mm soil depth excluding all drainage layers, waterproofing and protective screening will be provided for groundcovers. However, referring to the detail section in Drawing No. ST49/D2/EX/L/AS-400, only 200 mm soil depth is provided for the groundcovers on top of the covered walkway. Please review; and

Landscape Master Plan (Combined) (Drawing No. ST49/D2/EX/L/L/LO-000(S16)/A)

- (ii) the level of the landscape roof garden of the carport (+9.92) indicated in Drawing No. ST49/D2/EX/L/L/LO-000(S16) does not tally with ST49/D2/EX/L/L/LO-000(S16)/A. Please review.