

Responses-to-Comments

Item	Departmental Comments	Applicant's Responses
1. Comments from Fire Services Department (Received on 11.4.2024)		
1.	The provision of emergency lighting and directional and exit sign shall be clearly marked on plan;	Noted. Please refer to the attached Annex 1 .
2.	Fire extinguisher shall be provided in Guard Room; and	
3.	The G/F and 1/F of Logistic Centre 1 and 2 shall be regarded as separate compartments. As such, the calculation of openable windows shall be revised accordingly.	