

Response-to-Comments

	Departmental Comments	Responses
	<u>Fire Services Department (FSD)</u> (Contact: Mr. YUEN Tsz-fung at 2733-7781)	
(i)	A set of legible FSI proposal, particularly the section drawings with dimensions and calculation of all openable windows shall be provided.	Please see the attached revised Fire Service Installations Proposal.
(ii)	Modified hose reel system shall be provided in accordance with the Code of Practice for Minimum Fire Service Installations and Equipment 2022.	Please see the attached revised Fire Service Installations Proposal.
(iii)	The standards and specification of the proposed fire alarm system shall be revised to “BS 5839-1:2017 and the FSD Circular Letter No. 6/2021”.	Please see the attached revised Fire Service Installations Proposal.
(iv)	The standards and specification of the proposed emergency lighting shall be revised to “BS 5266-1:2016, BS EN 1838:2013 and the FSD Circular Letter No. 4/2021”.	Please see the attached revised Fire Service Installations Proposal.
(v)	The standards and specification of the proposed directional and exit signs shall be revised to “BS 5266-1:2016 and the FSD Circular Letter No. 5/2008”.	Please see the attached revised Fire Service Installations Proposal.