

Urgent Return receipt Expand Group Restricted Prevent Copy Confidential

**Hon Yip WONG/PLAND**

---

寄件者: [REDACTED]  
寄件日期: 2025年02月14日星期五 15:48  
收件者: Hon Yip WONG/PLAND  
副本: [REDACTED]  
主旨: RE: s.16 Planning Application No. A/K5/872 - Proposed Shop and Services at G/F,  
W668, 680 Castle Peak Road, Cheung Sha Wan, Kowloon  
  
類別: Internet Email

Dear Mr. Wong,

We confirm the fire resisting construction between the Premises on G/F and industrial portion on 1/F will be provided to the satisfaction of the Building Authority (BA);

We confirm that enclose of the slab opening of the internal staircase between the premises on G/F and the industrial portion on 1/F is to provide separate means of escape for the commercial portion on the G/F to meet relevant fire safety requirements.

Regards,  
Yin

**C&L ARCHITECTS & SURVEYORS LIMITED**

朱倫建築師測量師有限公司

[REDACTED]  
Unit 2, 16/F., Win Plaza, 9 Sheung Hei Street, San Po Kong, KLN.