Cheryl Tsz Man TSANG/PLA	ND
寄件者: 寄件日期: 收件者: 主旨: 附件:	PROJECT CONSULTANCY FBI < 2024年07月31日星期三 16:53 Cheryl Tsz Man TSANG/PLAND Re: Planning Application No. A/NE-FTA/248 Proposed Temporary Cargo Handling and Freight Forwarding Facilities for a Period of 3 Years 消防裝置布局圖_工作區域 1.jpg
類別:	Internet Email
有關 A/NE-FTA/248	回覆規劃署及消防署問題
Cheryl Tsz Man TSANG/PLA	ND < > 於 2024年7月30日週二下午5:03 寫道:
Dear Mr. Chan,	
Please find the comments Director of Fire Services	below for your information: (D of FS) (Contact Person: Mr. WAH Herbert Chi-lut, Tel:
the applicant is advised to Department for approval.	ign/nature of the proposal, FSIs are anticipated to be required. Therefore, submit relevant layout plans incorporated with the proposed FSIs to this n addition, the applicant should also be advised on the following points:
(ii) The location o layout plans.	f where the proposed FSI to be installed should be clearly marked on the
• • •	eminded that if the proposed structures are required to comply with the 123), detailed fire service requirements will be formulated upon receipt of ral building plans.

□Urgent □Return receipt □Expand Group □Restricted □Prevent Copy □Confidential

□Urgent □Return receipt □Expand Group □Restricted □Prevent Copy □Confidential <u>Director of Agriculture, Fisheries and Conservation (DAFC) (Contact Person: Ms. Chole NG, Tel:</u>
The applicant should clarify whether tree felling is involved and avoid impact to the nearby watercourse during construction and operation of the proposed use should the application be approved.
Best regards,
Cheryl Tsang
ATP/N2, Sha Tin, Tai Po and North District Planning Office,
Planning Department
Tel:
From: Cheryl Tsz Man TSANG/PLAND Sent: Monday, July 29, 2024 12:13 PM To: 'Subject: Planning Application No. A/NE-FTA/248 Proposed Temporary Cargo Handling and Freight Forwarding Facilities for a Period of 3 Years
Dear Mr. Chan,
Please find the comments of Head of the Geotechnical Engineering Office, Civil Engineering and Development Department (H(GEO), CEDD) (Contact Person: Mr. K. K. CHAN, Tel: for your information:
 It is noted from the site plans that the proposed development would affect or be affected by an unregistered slope with height greater than 6m located within 6m of the Site. In this regard

an unregistered slope with height greater than 6m located within 6m of the Site. In this regard, the applicant is required to submit a Geotechnical Planning Review Report (GPRR) in support of the captioned planning application, pursuant to Annex B of the Guidance Notes of the Application for Permission under Section 16 of the Town Planning Ordinance (Cap. 131). The essential contents of a GPRR are given in the attached GEO Advice Note.

□ Urgent □ Return receipt □ Expand Group □ Restricted □ Prevent Copy □ Confidential	
[attachment "GPRR Requirements.pdf" deleted by Cheryl Tsz Man TSANG/PLAND]	
Best regards,	
Cheryl Tsang	
ATP/N2, Sha Tin, Tai Po and North District Planning Office,	
Planning Department	
Tel:	