

Carman Chui Ying CHEUNG/PLAND

寄件者: Jeffrey Lam < >
寄件日期: 2024年03月11日星期一 3:59
收件者: Carman Chui Ying CHEUNG/PLAND
副本: Johnny Chung Yin LAM/PLAND; Katie Yuet Yee LEUNG/PLAND
主旨: Re: A/NE-HLH/71
附件: FI 03-11 Checking capacity of pipe.pdf; FI 03-11 Response to Comments.pdf; FI 03-11 Revised Drainage Proposal Section 6.pdf

類別: Internet Email

Dear Carman,

Please find attached FI to address comments from DSD. Thank you

1. Response to Comments
2. Calculations for checking capacity of 0.7m diameter pipe
3. Revised Page 5 of the Drainage proposal with updates to section 6

On Wed, Mar 6, 2024 at 5:01 PM Carman Chui Ying CHEUNG/PLAND <ccycheung@pland.gov.hk> wrote:

Dear Jeffrey,

Please find the following comments from Drainage Services Department (Mr Samuel Wang, Tel.: 2300 1135) for the captioned application:

- “1. Please check and advise if the existing 0.7m diameter pipe has adequate capacity and in satisfactory condition to cater for the additional discharge from the site and associated external catchment area. Also, please advise the existing upstream catchment area of the existing 0.7m dia. drainage pipe.
2. Please indicate the invert levels and catchpit types in the drainage proposal. Especially please specify the catchpits with sand trap.
3. Section 6 of drainage proposal refers. Two existing drainage channel are mentioned while only one is indicated in the Figure 2, please clarify.
4. Please provide photos of the existing catchpits proposed for connection to the west of the proposed development.
5. The “existing catchpit, pipe and channel” to which the applicant proposed to discharge the storm water from the subject site is **not** maintained by this office. Consent from the owner/maintenance party, current