

Urgent  Return receipt  Sign  Encrypt  Mark Subject Restricted  Expand personal&public groups



RE: DD39lot2048  
16/10/2020 16:54

From:  
To:  
Cc:



1 attachment



FIT Standard Metering Requirement (Chi)500x700 (1).pdf

Dear Michelle,

Related to our telephone conversation this afternoon, please find the following informations for your reference.

(C ) The meter box is ready for CLP Electric Meter installation, and the dimension is 700 (H) X 500 (W) X 250 (D). Please find the attached file for your record.

(D) The mounting of PV panel is metal stand.

(E) Regarding maintenance services, we will be on-site inspections with humans, no vehicle is required

Many thanks!!

Best regards,  
Jo Jo

From: Jo Jo Fung [redacted]  
Sent: Thursday, October 15, 2020 4:07 PM  
To: 'mltchan@pland.gov.hk' <mltchan@pland.gov.hk>; [redacted]  
Cc: [redacted]  
Subject: RE: DD39lot2048

Dear Michelle,

Many thanks for your mail, here please find our reply which bold in yellow for your reference.

(a) why the applicant only seeks to obtain a planning permission for five years only and what his/her plan about the solar panels after the five-year period is?

Reply : The planning permission should be renew after five years .

(b) while the applicant indicated in the layout plan in the application that a solar energy system of **32kW** will be installed, we also note that in CLP's letter of 5 December 2019 attached to the application, the applicant seeks to install a solar PV system of **40kW**. Which should be the applicant finalised plan?

Reply : Our application should be bigger size than the installation so that CLP will no comment or rejection.

Should there be any queries, please do not hesitate to contact us at [REDACTED]

Best regards,

Jo Jo

Project Manager

*Kellon Energy Performance Contracting Limited*

*Kellon E & M Limited*

*Kellon Green Energy Limited*

HK mobile : [REDACTED]

Hotline:(HK) [REDACTED]

Website: [www.kellon.net](http://www.kellon.net)

Email: [REDACTED]

圖 2: 標準室外電錶箱 (上網電價) (單相 60 安培或三相 100 安培)

