

**S.16 Application - Temporary Public Vehicle Park (Private Cars Only) for a Period of 3 Years
at Lots 882 S.A and 882 RP in D.D. 19, She Shan Village,
Tai Po, New Territories
(Application No. A/NE-LT/774)**

No.	Comments	Responses
	<p>From: Chief Engineer/Construction, WSD, dated 7.1.2025 Contact: Ms. Victoria SUEN</p>	
1.	<p>Oil leakage and spillage are not allowed within WGG at all times. Since there will be potential risks of oil leakage from the vehicles parked inside the application site, the applicant shall confirm whether any oil and grease decontamination kit such as absorbent pads shall be made available within the site, or any effective control measures will be taken to mitigate the risks.</p>	<p>Noted, absorbent pads will be provided within the site to mitigate the risks.</p>
2.	<p>It is noted in the FI that drainage channels with petrol interceptors will be provisioned on site for interception in surface run-off. In this regard, I presume that the acceptance of the drainage proposal and its implementation are subject to the jurisdiction of the DSD.</p>	<p>Considering the application site with a relatively small area, please note that grease traps will be provided as drainage traps at the drainage outlet first, the petrol interceptors will be further considered if the grease traps are found unsatisfactory. The drainage proposal and its implementation will be subject to the satisfaction of the Drainage Services Department (DSD).</p>