

## FIRE SERVICE (INSTALLATIONS AND EQUIPMENT) REGULATIONS

消防(裝置及設備)規例

(Regulation 9(1))

(第九條(1)款)

## CERTIFICATE OF FIRE SERVICE INSTALLATION AND EQUIPMENT

消防裝置及設備證書

FSD Ref.:

消防處權號

Serial Number

30205 106654

Name of Client 顧客姓名

Sha Tau Kok Farm Organic Company Limited

Address 地址

30G Tong To Village, DD41 Lot 447SB, Sha Tau Kok, NT



Type of Building 樓宇類型:

Industrial 工業

Commercial 商業

Domestic 住宅

Composite 綜合

Licensed premises 持牌處所

Institutional 社團

**Part 1 Annual Maintenance ONLY****第一部 只適用於年檢事項**

In accordance with Regulation 8(b) of the Fire Service (Installations and Equipment) Regulations, the owner of any fire service installation or equipment which is installed in any premises shall have such fire service installation or equipment inspected by a registered contractor at least once in every 12 months. 根據消防(裝置及設備)規例第八條(b)款, 擁有裝置在任何處所內的任何消防裝置或設備的人, 須每12個月由一名註冊承辦商檢查該等消防裝置或設備至少一次。

| Code 編碼 (1-35) | Type of FSI 裝置類型 | Location(s)位置 | Comment on Condition 狀況評述 | Completion Date 完成日期 (DD/MM/YYYY) | Next Due Date 下次到期日 (DD/MM/YYYY) |
|----------------|------------------|---------------|---------------------------|-----------------------------------|----------------------------------|
|                |                  |               |                           |                                   |                                  |
|                |                  |               |                           |                                   |                                  |

**Part 2 第二部 Installation / Modification / Repair / Inspection works 裝置/改裝/修理/檢查工作**

| Code 編碼 (1-35) | Type of FSI 裝置類型      | Location(s)位置 | Nature of Work Carried out 完成之工作內容 | Comment on Condition 狀況評述      | Completion Date 完成日期 (DD/MM/YYYY) |
|----------------|-----------------------|---------------|------------------------------------|--------------------------------|-----------------------------------|
| 24             | 5kg CO2 F.E. x 3 nos. | 30G, G/F      | Supply and Install                 | Conforms with FSD requirements | 06/05/2024                        |
|                |                       |               |                                    |                                |                                   |

**Part 3 第三部 Defects 損壞事項**

| Code 編碼 (1-35) | Type of FSI 裝置類型 | Location(s)位置 | Outstanding Defects 未修缺點 | Comment on Defects 缺點評述 |
|----------------|------------------|---------------|--------------------------|-------------------------|
|                |                  |               |                          |                         |
|                |                  |               |                          |                         |

Remark 備註

I/We hereby certify that the above installations/equipment have been tested and found to be in efficient working order in accordance with the Codes of Practice for Minimum Fire Service Installations and Equipment and Inspection, Testing and Maintenance of Installations and Equipment published from time to time by the Director of Fire Services. Defects are listed in Part 3.

本人藉此證明以上之消防裝置及設備經試驗, 證明性能良好, 符合消防處處長不時公佈之最低限度之消防裝置及設備守則與裝置及設備之檢查測試及保養守則的規格, 損壞事項列於第三部。

**如證書涉及年檢事項, 應張貼於大廈或處所當眼處以供消防處人員查核**

**This certificate should be displayed at prominent location of the building or premises for FSD's inspection if any annual maintenance work is involved.**

Authorized

Signature:

受權人簽署

Name:

姓名

潘正強

FSD/RC No.:

消防處註冊號碼

RC3

/ 0205

RC

/

Company Name:

公司名稱

潘正強

Telephone:

聯絡電話

Date:

日期

06/05/2024

For FSD use only

Inspected

Key-in

Verified



Serial Number

30205 106654

Name of Client 顧客姓名

Sha Tau Kok Farm Organic Company Limited

