



Inside CA
Item 5: 2m(L) x 1m(W) x 1.8m(D) x 7.2m (H)
S16 will be applied

Inside CA
Item 2: 9m(L) x 1m(W) x 1.2m(D)
S16 will be applied

Inside CA
Item 6: 2m(L) x 1m(W) x 1.8m(D) x 2m (H)
S16 will be applied

Inside CA
Item 3: 13m(L) x 1m(W) x 1.2m(D)
S16 will be applied

Inside CA
Item 1a: 135m(L) x 1m(W) x 1.2m(D)
S16 will be applied

Inside CA
Item 4: 2m(L) x 1m(W) x 1.8m(D) x 7.2m (H)
S16 will be applied

- LEGEND :
- PROPOSED TRENCH FOR LAYING / RECOVERING CABLE
 - (NO) PROPOSED TRENCH FOR LAYING DUCTS
 - = PROPOSED CABLE THROUGH EXISTING DUCTS
 - EXISTING PILLAR
 - PROPOSED PILLAR 1.6M x 0.6M x 0.75M / CUTOUT BOX
 - x EXCAVATION FOR JOINTING / REPAIRING / INSPECTING CABLE
 - ⊠ PROPOSED 3.6M(L) x 3.32M(W) x 2.7M(H) HV PILLAR
 - EXISTING OVERHEAD LINE & POLE
 - PROPOSED 11kV, L.V., OHL, OF STEEL / WOODEN POLE
 - x OVERHEAD LINE & POLE TO BE REMOVED
 - ⊠ PROPOSED TREE TRIMMING / CUTTING
 - ▲ EXISTING POLE MOUNTED TRANSFORMER
 - ▲ PROPOSED POLE MOUNTED TRANSFORMER
 - + PROPOSED STAY / STAY POLE



TITLE : 11KV CABLE LAYING, POLE ERECTION
AT SIU HANG HAU ROAD
SIU HANG HAU
SAI KUNG

SCALE 1:1000
DATE : 04-12-2023
REGION : WE
O.C. : SK

DRAWN : H.Y. WONG
CHECKED :
E/O NO :
PROJECT REF. : SK2021-0020
PLAN REF. : WESK2021-0020-02