

Comments from the Environmental Protection Department dated 27.5.2024

Contact Person: Mr. Danny LO; Tel: 2594 6513

	Comments	Responses
i)	What are the output power of the proposed EV chargers to be installed?	The output power of the proposed EV chargers is 21kW per charger.
ii)	Will fee-charging payment be required for using these EV chargers? If affirmative, any smart systems (e.g. display boards showing the EV charging space availability information, occupancy sensors, etc.) including payment system will be installed?	No fee will be charged for using these EV chargers. No smart system will be installed.