

Response-to-Comments

	Departmental Comments	Responses
	<u>Environmental Protection Department (EPD)</u> (Contact: Mr. Jeremy FONG at 2835 2164)	
	The applicant should confirm whether septic tank and soakaway system will be provided and if affirmative, whether the septic tank and soakaway system will be designed and constructed according to the requirements of EPD's ProPECC PN 1/23, including requirements for minimum clearance distance, percolation test and certification by Authorized Person.	Please note that septic tank and soakaway system would not be provided in this planning application as the proposed toilet would be a mobile type. However, the Applicant would comply with the requirements of EPD's ProPECC PN 1/23 if it is necessary to provide septic tank and soakaway system in future.