## DEVELOPMENT PARAMETERS OF THE APPLICATION SITE

: 1,483 m<sup>2</sup> : 454 m<sup>2</sup> APPLICATION SITE AREA (ABOUT) COVERED AREA (ABOUT) : 1,029 m<sup>2</sup> UNCOVERED AREA (ABOUT)

PLOT RATIO : 0.37 (ABOUT) SITE COVERAGE (ABOUT) : 31%


NO. OF STRUCTURE : 10

DOMESTIC GFA : NOT APPLICABLE NON-DOMESTIC GFA : 562 m<sup>2</sup> (ABOUT) (ABOUT) TOTAL GFA

BUILDING HEIGHT : 3 m - 7 m (ABOUT)

NO. OF STOREY :1-2

STRUCTURE	USE	COVERED AREA	GFA	BUILDING HEIGHT
B1	FINANCIAL INSTITUTION & OFFICE	59 m² (ABOUT)	95 m² (ABOUT)	7 m (ABOUT)(2-STOREY)
B2	FINANCIAL INSTITUTION & OFFICE	95 m² (ABOUT)	167 m² (ABOUT)	7 m (ABOUT)(2-STOREY)
B3	WASHROOM	COVERED BY B8	COVERED BY B8	3.5 m (ABOUT)(1-STOREY)
B4	EATING PLACE	COVERED BY B8	COVERED BY B8	3.5 m (ABOUT)(1-STOREY)
B5	EATING PLACE	COVERED BY B7	COVERED BY B7	3.5 m (ABOUT)(1-STOREY)
B6	EATING PLACE	COVERED BY B7	COVERED BY B7	3.5 m (ABOUT)(1-STOREY)
B7	RAIN SHELTER (SHED STRUCTURE)	175 m² (ABOUT)	175 m <sup>2</sup> (ABOUT)	4 m (ABOUT)(1-STOREY)
B8	RAIN SHELTER (SHED STRUCTURE)	110 m² (ABOUT)	110 m <sup>2</sup> (ABOUT)	4 m (ABOUT)(1-STOREY)
B9	STORAGE OF GOODS	7 m² (ABOUT)	7 m <sup>2</sup> (ABOUT)	3m (ABOUT)(1-STOREY)
B10	WASHROOM	8 m² (ABOUT)	8 m <sup>2</sup> (ABOUT)	3m (ABOUT)(1-STOREY)
	TOTAL	454 m <sup>2</sup> (ABOUT)	562 m <sup>2</sup> (ABOUT)	









TEMPORARY SHOP (FINANCIAL SERVICES INSTITUTION) AND EATING PLACE WITH ANCILLARY FACILITIES FOR A PERIOD OF 3 YEARS

VARIOUS LOTS IN D.D. 104 AND ADJOINING GOVERNMENT LAND, SAN TAM ROAD, KAM TIN, YUEN LONG, NEW TERRITORIES

SCALE				
1 : 350 @ A4				
DRAWN BY	DATE			
MN	28.5.2024			
REVISED BY	DATE			
APPROVED BY	DATE			
DWG. TITLE				
LAYOUT PLAN				

PARKING SPACE

LOADING / UNLOADING SPACE

DWG NO. APPENDIX II 001

## FIRE SERVICE INSTALLATIONS

EMERGENCY LIGHT

EXIT SIGN

EXIT

5 KG CO2 TYPE FIRE EXTINGUISHER

## FS NOTES:

- 1. SUFFICIENT EMERGENCY LIGHTING SHALL BE PROVIDED THROUGHOUT THE ENTIRE BUILDING IN ACCORDANCE WITH BS5266-1:2016 AND BS EN1838:2013 AND FSD CIRCULAR LETTER 6/2021
- 2. SUFFICIENT DIRECTIONAL AND EXIT SIGN SHALL BE PROVIDED IN ACCORDANCE WITH BS5266-1:2016 AND FSD CIRCULAR LETTER 5/2008.
- HAND-OPERATED PORTABLE APPROVED APPLIANCE SHALL BE PROVIDED AS REQUIRED BY OCCUPANCY.
- 4. ACCESS IS PROVIDED FOR EMERGENCY VEHICLE TO REACH 30m OF ALL PART OF STRUCTURES.