

Date: 23rd October 2024

Page(s): 1 + Attachment
BY HAND & EMAIL
(tpbpd@pland.gov.hk)

Secretary, Town Planning Board 15/F, North Point Government Offices 333 Java Road, North Point, Hong Kong

Dear Sir/Madam.

SECTION 16 APPLICATION TOWN PLANNING ORDINANCE (CHAPTER 131)

APPLICATION FOR PERMISSION UNDER SECTION 16 TOWN PLANNING APPLICATION FOR THE PROPOSED TEMPORARY WAREHOUSE (EXCLUDING DANGEROUS GOODS GODOWN) FOR A PERIOD OF 3 YEARS AND ASSOCIATED FILLING OF LAND IN "AGRICULTURE" ZONE IN LOT NOS. 956 AND 959 RP IN D.D. 107, FUNG KAT HEUNG ROAD, KAM TIN, YUEN LONG, NEW TERRITORIES

(Town Planning Application No. A/YL-KTN/1052 – Submission of Further Information 2)

We refer to the captioned town planning application.

Attached please find 4 copies of the Revised Fire Service Installation Proposal for further clarification:

Please be advised that this FI should be exempted from the publication requirement and/or the recounting requirement in accordance with TPB PG-No. 32B since the replacement pages of the report is only a technical clarification/response to comments of relevant Government department WITHOUT changing the nature of the application, the proposed uses nor the proposed scheme.

We should be most grateful if you can notify us of any departmental comments or queries on the application for our corresponding action in due course.

Should you have any queries with this pre-submission, please feel free to contact Mr. Calton HEUNG at contact or the undersigned at contact.

Yours faithfully, FOR AND ON BEHALF OF DeSPACE (INTERNATIONAL) LIMITED

Greg Lam



PROJECT: PROPOSED TEMPORARY WAREHOUSE IN KAM TIN

SUBJECT: F.S. NOTES

- 1. THE WHOLE OF THE FIRE SERVICES INSTALLATIONS SHALL COMPLY WITH THE CODES OF PRACTICE ISSUED BY THE HONG KONG FIRE SERVICES DEPARTMENT.
- 2. ANY INTENDED STORAGE OR USE OF DANGEROUS GOODS AS DEFINED IN CHAPTER 295 OR THE LAWS OF HONG KONG SHOULD BE NOTIFIED TO THE DIRECTOR OF FIRE SERVICES.
- 3. EMERGENCY LIGHTING SHALL BE PROVIDED THROUGHOUT THE ENTIRE AREA AND COMPLY WITH BS STANDARD BS 5266-1:2016, BS EN STANDARD 1838:2013 AND FSD CIRCULAR LETTER 4/2021.
- 4. SUFFICIENT DIRECTIONAL AND EXIT SIGNS TO ENSURE THAT ALL EXIT ROUTES ARE CLEARLY INDICATED AS REQUIRED BY THE CONFIGURATION SERVING THE AREA, AND COMPLY WITH BS 5266-1:2016 AND FSD CIRCULAR LETTER NO. 5/2008 AND FSD'S CODE OF PRACTICE 2022 EDITION. THE DIRECTIONAL AND EXIT SIGNS SHALL BE BACKED UP BY BATTERY.
- 5. MANUAL FIRE ALARM SYSTEM IN ACCORDANCE WITH BS5839-1:2017 AND FSD CL 6/2021 SHALL BE PROVIDED FOR ENTIRE AREA AND INCORPORATED WITH MODIFIED HOSE REEL SYSTEM.
- 6. THE MANUAL CALL POINT SHALL INCLUDE FACILITIES FOR FIRE PUMP START AND AUDIO ALARM BELL.
- 7. ONE ACTUATING POINT AND ONE AUDIO WARNING DEVICE TO BE LOCATED AT EACH HOSE REEL POINT. VISUAL ALARM SIGNALS SHALL BE PROVIDED WHERE NECESSARY IN ACCORDANCE WITH CURRENT DESIGN MANUAL BARRIER FREE ACCESS. THIS ACTUATING POINT SHALL INCLUDE FACILITIES FOR FIRE PUMP START AND AUDIO/ VISUAL WARNING DEVICE INITIATION.
- 8. MODIFIED FIRE HOSE REEL SYSTEM
 - i. THERE SHALL BE SUFFICIENT HOSE REELS TO ENSURE THAT EVERY PART OF THE AREA CAN BE REACHED BY A LENGTH OF NOT MORE THAT 30 M OF FIRE SERVICES HOSE AND HOSE REEL TUBING.
 - ii. ONE 2,000 LITRES FIRE SERVICES WATER TANK TO BE PROVIDED FOR THE FIRE HOSE REEL SYSTEM FOR ENTIRE AREA.
 - iii. THE FIXED FIRE PUMPS (ONE DUTY AND ONE STANDBY) IN FS PUMP ROOM AT GROUND FLOOR.
- 9. 4.5 KG CO2 FIRE EXTINGUISHERS TO BE PROVIDED IN ALL PLANT ROOMS AND AT POSITION AS INDICATED ON PLANS.
- 10. SECONDARY POWER SUPPLY WILL BE PROVIDED FOR ALL FIRE SERVICES INSTALLATIONS AND CONNECTED BEFORE MAIN SWITCH EXCEPT EMERGENCY LIGHTING, DIRECTIONAL SIGNS AND EXIT SIGNS.

(N.T.S. @ A3)

