DEVELOPMENT PARAMETERS STRUCTURE USE : 516 m² (ABOUT) APPLICATION SITE AREA COVERED AREA : 222 m² (ABOUT) WAREHOUSE (EXCLUDING D.G.G.) В1 UNCOVERED AREA : 294 m² (ABOUT) ANCILLARY OFFICE (ABOUT) PLOT RATIO : 0.43 SITE COVERAGE : 43 % (ABOUT) NO. OF STRUCTURE DOMESTIC GFA : NOT APPLICABLE NON-DOMESTIC GFA : 222 m² (ABOUT) TOTAL GFA : 222 m² (ABOUT) BUILDING HEIGHT : 8.23 m (ABOUT) NO. OF STOREY PARKING AND LOADING/UNLOADING PROVISION NO. OF PRIVATE CAR PARKING SPACE DIMENSION OF PARKING SPACE : 5 m (L) X 2.5 m (W) NO. OF LIGHT GOODS VEHICLE PARKING SPACE : 1 DIMENSION OF LOADING/UNLOADING SPACE : 7 m (L) X 3.5 m (W)

INGRESS / EGRESS 7.3m (ABOUT)(W)

APPLICATION SITE **B1** FΕ LEGEND







PROPOSED TEMPORARY WAREHOUSE (EXCLUDING DANGEROUS GOODS GODOWN) FOR A PERIOD OF 3 YEARS AND ASSOCIATED FILLING OF LAND

APPLICATION NO. A/YL-KTN/1083

ANNEX I

LOTS 1222 S.A (PART) AND 1224 S.B. IN D.D. 107, FUNG KAT HEUNG, KAM TIN, YUEN LONG, NEW TERRITORIES

SCALE	
1:200 @ A4	
DRAWN BY	DATE
LT	7.2.2025
CHECKED BY	DATE
APPROVED BY	DATE
DWG. TITLE	
FSIs PROPOSAL	

001

APPLICATION SITE STRUCTURE

PARKING SPACE

LOADING / UNLOADING SPACE

COVERED

222 m² (ABOUT)

222 m² (ABOUT)

AREA

TOTAL

GFA

222 m² (ABOUT)

222 m² (ABOUT)

BUILDING

8.23 m (ABOUT)(1-STOREY)

HEIGHT

INGRESS / EGRESS

FIRE SERVICE INSTALLATIONS

EXIT SIGN

FS NOTES:

3.

EMERGENCY LIGHTING

AND FSD CIRCULAR LETTER No. 5/2008.

REACH 30m OF ALL PART OF STRUCTURES.

5 KG DRY POWDER TYPE FIRE EXTINGUISHER

SUFFICIENT EMERGENCY LIGHTING SHALL BE PROVIDED THROUGHOUT THE ENTIRE BUILDING IN ACCORDANCE WITH BS5266-1:2016 AND BS EN1838:2013 AND FSD CIRCULAR LETTER NO. 4/2021 SUFFICIENT DIRECTIONAL AND EXIT SIGN SHALL BE

PROVIDED IN ACCORDANCE WITH BS5266-1: 2016

PORTABLE HAND-OPERATED APPROVED APPLIANCE

SHALL BE PROVIDED AS REQUIRED BY OCCUPANCY.

ACCESS IS PROVIDED FOR EMERGENCY VEHICLE TO