



*All FSI (includes installation/maintenance/modification/repair work) is already completed by RFSIC.
*Please see F.S. 251 - A9079075 and A9079304 for the latest Annual Inspection of FSI.
*For Emergency Vehicular Access, Please see Appendix 1.1
*All the enclosed structures are provided with access for emergency vehicles to reach within 30m travel distance from the structures.

Legend:

- 5 kg Portable Dry Powder Type Fire Extinguisher (1 in Total)
- 9 kg Portable Foam Type Fire Extinguisher (1 in Total)
- Emergency Lighting (2 in Total)
- ▤ Exit Signs (2 in Total)

Appendix 1

Location: DD 109 Lot 367 RP (Part)
App. No.: A/YL-KTS/1024

OZP: S/YL-KTS/15
District: Kam Tin South
Zoning: Village Type Development

Date: 17 October 2024

Fire Service Installation Plan

消防設備安裝計劃圖

擬議臨時商店及服務行業（地產代理）
為期3年

Proposed Shop and Services
(Real Estate Agency)
For a Period of 3 Years

SCALE

1:100

@A4

For Identification Only

Drawing No.:

1-01



Scale: Undefined @A4

Captured from map.gov.hk on 22nd August 2024

<p>Appendix 1.1 Emergency Vehicular Access</p>	<p>Location: D.D. 109 Lot 367 RP (Part) OZP: S/YL-KTS/15 District: Kam Tin South Zoning: Village Type Development Zone</p>	<p>Project: Proposed Temporary Shop and Services (Real Estate Agency) For a Period of 3 Years</p>	<p>Width of Kam Sheung Road: 6m (About)</p> <p>Map Legend: ●●●● Road Path — Site Boundary</p>	<p>Drawing No.: 1-1.1</p> <p>For Identification Only</p> <p>Date: 22/08/2024</p>
---	--	---	---	--