

寄件者:
寄件日期: 2024年04月11日星期四 15:30
收件者: tpbpd/PLAND
副本: Gary Tat Leung LAM/PLAND; YL-TKE; Ryan Long Yin CHAN/PLAND
主旨: Application No. A/YL-MP/362 (YL-230545)
類別: Internet Email

Dear Town Planning Board,

We provide the comments for clarify the service targets of the proposed public utility installation and whether the installation is essential.

For Applicant information, the electricity power supply of applicant is Highway Department, Lighting Division.

To illustrate why the installation is necessary, the purpose of applying electricity is for a new public utility installation, namely a public lighting .

Insufficient public lighting facilities along Tai Tseng Wai, so this new public lighting can reduce the occurrence of night driving accidents and convenient public to use.

We clarify that the standard voltage is 380V that the type of underground cable is 300 4 core AL.

Best Regards,
Manfred
Tel: