


建築物編號 STRUCTURE	用途 USE	層數 STOREY	高度 BUILDING HEIGHT	大約上蓋面積 GFA(ABOUT)	Fire Notes:		
B1	農具展覽室	2	5.2m	30sq.m (上層: 15sq.m, 下層: 15.sq.m)	<p>1.Sufficient emergency lighting shall be provided throughout the entire building in accordance with BS5266-1:2016 and BS EN 1838:2013 and the FSD Circular Letter no.4/2021.</p> <p>2.Sufficient directional and exit sign shall be provided in accordance with BS 5266-1:2016 and FSD Circularsr letter No 5/2008.</p> <p>3.Sufficient portable hand-operated approved appliance shall be provided as required by occupancy and as marked on plans.</p> <p>4.A hose reel system should be provided in accordance with the FSI Cop 2022. The hose reel system should be supplied by a 2.0m³ F.S Water tank. There shall be sufficient hose reel to ensure that every part of each buildind can be reached by a length of not more than 30m of hose reel tubing.The F.S water tank, F.S pump room and hose reel shall be clearly marked on plans.</p> <p>5.Fire alarm system shall be provided throughout the entire building in accordance with BS 5839-1:2017 and the FSD Circular Letter 6/2021 . One actuation point and one audio warning device to be located at each hose reel point.The actuation point should include facilities for fire pump start and audio/Visual warning device initiation.</p> <p>6.Hose Reel pump(HR-P1,HR-P2&HR-JP) and 1.no 5kg co2 type fire extinguisher shall be provided at F.S pump Room.</p> <p>7.Source of secondary power supply for FSI shall be provided.</p>		
B2	寵物園	1	3.6m	46sq.m			
B3	演講室	2	5.6m	228sq.m (上層: 108sq.m, 下層: 120sq.m)			
B4	小食部	1	2.7m	18sq.m			
B5	免仔房連通風棚	1	3.5m	122sq.m (房: 18sq.m, 通風棚 104sq.m)			
B6	兒童教學室	2	5.3m	229sq.m (上層: 15sq.m, 下層: 214sq.m)			
B7	兒童教學走廊	1	3.5m	111sq.m			
B8	多功能兒童活動室	2	6.5m	229.m (上層: 110sq.m, 下層: 119sq.m)			
B9	有蓋廣場 (通風棚)	1	5.2m	936sq.m			
B10	觀星台 (通風棚)	1	2.8m	73sq.m			
B11	倉庫	1	3.5m	15sq.m			
B12	園藝工作坊連通風棚	1	3.8m	89sq.m (工作坊 45sq.m, 通風棚 44sq.m)			
B13	雨天活動場地 (通風棚)	1	5.2m	154sq.m			
B14	廁所	1	3.0m	5.0sq.m			
INTERCEPT FIRE & SECURITY TECHNICIANS LIMITED 			Project: Proposed Temporary Place of Recreation, Sports or Culture and Barbecue Site with Ancillary Facilities for a Period of 3 years and Associated Filling of Land and Pond At Various Lots in D.D.111 and Adjoining Government Land,Pat Heung,Yuen Long		Title: Proposed Fire Service Installation Layout Plan		Drawn by: W.C.WONG
					Date: 2024-10-14		
					Scale: NO Scale @ A3		
					Ref No:		
					Drawing No: 2/2P		



INTERCEPT FIRE & SECURITY
TECHNICIANS LIMITED



Project:
Proposed Temporary Place of
Recreation, Sports or Culture
and Barbecue Site with Ancillary
Facilities for a Period of 3 years
and Associated Filling of Land
and Pond At Various Lots in
D.D.111 and Adjoining Government
Land, Pat Heung, Yuen Long

Title:
Proposed Fire Service
Installation Layout Plan

Drawn by: W.C.WONG
Date: 2024-10-14
Scale: 1:400@ A2
Ref No:
Drawing No: 1/2P