

Urgent Return receipt Expand Group Restricted Prevent Copy

From: king king <[REDACTED]>
Sent: 2024-12-30 星期一 19:46:15
To: [REDACTED]
Cc: [REDACTED]
Subject: tpbpd/PLAND <tpbpd@pland.gov.hk>
Re: A/YL-SK/397 Departmental Comments - FSD
Attachment: SK397-ltr-06.pdf

Dear Charlotte,

Please see attached letter for responding to D of FS's comments. Thank you.

Best Regards,

Patrick Tsui

Mobile: [REDACTED]

Total: 2 pages

Date: 30 December 2024

TPB Ref.: A/YL-SK/397

By Email

Town Planning Board
15/F, North Point Government Offices
333, Java Road
North Point
Hong Kong
(Attn: The Secretary)

Dear Sir,

**Temporary Shop and Services (Shop for Selling Vehicle Spare Parts)
for a Period of 3 Years at Lot 878 (Part) in D.D.114 & Adjoining
Government Land, Pat Heung, Yuen Long, N.T.**

The comments of the Director of Fire Services is noted. Please see the updated FSI plan in the attachment.

Should you have any enquiries, please feel free to contact our Mr. Patrick Tsui at [REDACTED] [REDACTED] at your convenience.

Yours faithfully,






Patrick Tsui

c.c. Fanling, Sheung Shui and Yuen Long East District Planning Office (Attn: Ms. Charlotte CHI) – By Email



F.S. Notes

- i. Provision of FSIs shall be demonstrated in form of FS Notes with all relevant standards and specifications;
- ii. Emergency lighting shall be provided in accordance with BS 5266-1:2016, BS EN 1838:2013 and the FSD Circular Letter No. 4/2021; and
- iii. Sufficient directional and exit signs shall be provided in accordance with BS 5266-1:2016 and the FSD Circular Letter No. 5/2008.



Project 項目名稱:

Temporary Shop and Services (Shop for Selling Vehicle Spare Parts) for a Period of 3 Years at Lot 878 (Part) in D.D.114 & Adjoining Government Land, Pat Heung, Yuen Long, N.T.

Drawing Title 圖目:

Proposed Fire Service Installations Plan

Drawing No. 圖號:

Figure 5

Remarks 備註:

- 出口 Exit Sign
- 緊急照明燈 Emergency Light
- 5kg carbon dioxide fire extinguisher

Scale 比例:

1:500