

規 劃 署

屯門及元朗西規劃處
香港新界沙田上禾輦路一號
沙田政府合署 14 樓



By Fax [REDACTED] & Post
Planning Department

Tuen Mun and Yuen Long West
District Planning Office
14/F, Sha Tin Government Offices,
1 Sheung Wo Che Road, Sha Tin, N.T.
Hong Kong

來函檔號 Your Reference 21/711/L05
本署檔號 Our Reference () in TPB/A/YL-TT/523
電話號碼 Tel. No. : 2158 6296
傳真機號碼 Fax No. : 2489 9711

23 November 2021

Top Bright Consultants Ltd.
Room 103
300 Kung Um Road
Yuen Long, New Territories
[REDACTED]

Dear Sir,

Compliance with Approval Condition (j) **Planning Application No. A/YL-TT/523**

I refer to your submission dated 11.11.2021 for compliance with the captioned approval condition on the submission of a fire service installations (FSIs) proposal. The Fire Services Department (FSD) has been consulted on your submission. Your submission is considered:

- Acceptable. The captioned condition **has been complied** with. Please find detailed advisory departmental comments at **APPENDIX**.
- Acceptable. Since the captioned condition requires both the submission and implementation of the proposal, it **has not been fully complied with**. Please proceed to implement the accepted proposal for full compliance with the approval condition.
- Not acceptable. The captioned condition has **not** been complied with. Please find detailed advisory departmental comments at **APPENDIX**.

Should you have any queries on the departmental comments, please contact Mr. WONG Ho-yin (Tel: 2733 7737) or Mr. LI Leong-kiu (Tel: 2733 7781) of FSD.

Yours faithfully,

(K. K. NG)

for District Planning Officer/
Tuen Mun and Yuen Long West
Planning Department

c.c.

D of FS (Attn.: Mr. WONG Ho-yin)

Internal

CTP/TPB (2)

KKN/AL/al

Comments of the Director of Fire Services (D of FS)

You are advised that the installation/ maintenance/ modification/ repair work of fire service installation (FSI) shall be undertaken by a Registered Fire Service Installation Contractor (RFSIC). The RFSIC shall after completion of the installation/maintenance/ modification/ repair work issue to the person on whose instruction the work was undertaken a certificate (FS 251) and forward a copy of the certificate to the Director of Fire Services.