

Urgent Return receipt Expand Group Restricted Prevent Copy

Momo Hei Ching CHOW/PLAND

寄件者: [REDACTED]
寄件日期: 2025年02月28日星期五 15:26
收件者: Momo Hei Ching CHOW/PLAND
副本: Eva Ka Yan TAM/PLAND; tpbpd/PLAND
主旨: Re: A/YL-TT/699 (Departmental Comments)
類別: Internet Email

Dear Momo,

We confirm that septic tank and soakaway system will be provided at the application site. The septic tank and soakaway system will be designed and constructed according to the requirements of EPD's ProPECC PN 1/23, including requirements for minimum clearance distance, percolation test and certification by Authorized Person.

Best Regards,

Patrick Tsui

Mobile: [REDACTED]

On Thursday, February 20, 2025 at 05:02:28 PM GMT+8, Momo Hei Ching CHOW/PLAND <mhcchow@pland.gov.hk> wrote:

Dear Sir/Madam,

As per your request, please find the departmental comments below for your action please.

A/YL-TT/699

Comments from EPD (Contact Person: Mr. Fong, Tel: 2835 2164)

(a) confirm that whether septic tank and soakaway system will be provided and if affirmative, whether the septic tank and soakaway system will be designed and constructed according to the requirements of EPD's ProPECC PN 1/23, including requirements for minimum clearance distance, percolation test and certification by Authorized Person.

Should you wish to submit further information in response to the above, please do so preferably as soon as possible in writing to Secretary of the Town Planning Board (Address: 15/F, North Point Government Offices, 333 Java Road, North Point, Hong Kong; Fax: 2877 0245) with a copy to us. In submitting the further information, reference should be made to the TPB Guidelines No. 32B on the Submission of Further Information in Relation to Applications for Amendment of Plan, Planning Permission and Review.

Urgent Return receipt Expand Group Restricted Prevent Copy

Alternatively, you can request the TPB to defer the consideration of the application in order to allow more time to prepare the further information. For details, please refer to the TPB Guidelines No. 33B on Deferment of Decision on Representations, Comments, Further Representations and Applications. Both guidelines could be retrieved from the TPB website: https://www.tpb.gov.hk/en/resources/tpb_guidelines/index.html.

Best Regards,
Momo CHOW
Tel.: 2158 6361
for District Planning Officer/Tuen Mun and Yuen Long West

Planning Department

