

Planning Application No. A/YL/319 - Location of Proposed Run-in/out and the Existing Lamppost

2 封郵件

Chi Chung Heung <caltondespace@gmail.com>

2024年7月10日 下午2:33

收件者: deyle.nt@hyd.gov.hk

副本: Greg Lam <greg@despacehk.com>, Cheng Endy <endydespace@gmail.com>, W K Kwong <wkwong@ctaconsultants.com>, Claudia Yim <claudiayim@ctaconsultants.com>, kelvinleung@ctaconsultants.com

Dear Mr. Choi,

Reference is made to the TD's comment on the captioned planning application as at 4 July 2024 (see attachment).

To address TD's comment on the location of proposed run-in/out and existing lamppost in the revised TIA, grateful if you could provide comments, if any (comment (q), extracted below in (1)). Figure 2.2 is extracted below in (2).

Should there be any queries, please do not hesitate to contact Mr. Calton Heung at 2493-3626. Thank you.


Best regards,
Calton Heung

DeSPACE (International) Limited

(1) TD's comments on the location of proposed run-in/out and existing lamppost:

(q) Figure 2.2: The location of run-in/out is close to the existing lamppost, please seek comment from Highways Department;

(2) Proposed run-in/out extracted from the revised TIA (Figure 2.2):

 Virus-free. www.avast.com 20240704 A_YL_319_Departmental Comments to Applicant.pdf
304K

deyle.nt@hyd.gov.hk <deyle.nt@hyd.gov.hk>

2024年7月10日 下午4:14

收件者: Chi Chung Heung <caltondespace@gmail.com>

副本: Claudia Yim <claudiayim@ctaconsultants.com>, Cheng Endy <endydespace@gmail.com>, Greg Lam <greg@despacehk.com>, kelvinleung@ctaconsultants.com, W K Kwong <wkwong@ctaconsultants.com>, pcci.ltg@hyd.gov.hk, sdenw.nt@hyd.gov.hk

Dear Calton,

Please find the following comments from our Lighting Division from public lighting point of view, for your follow-up action:

1. The proposed works shall not disturb, interfere with or damage the public lighting facilities (i.e. lamppost no. FC4715 and associated lighting cables).

2. The applicant shall submit the lighting works proposal supported by lighting simulation to this Division for consideration if there are any proposed modification works to the existing public lighting system or new lighting works involved in the project. The lighting proposals shall comply with the latest Public Lighting Design Manual and Standard Drawings of the Highways Department. The cost for the relevant works should be funded by the applicant.

3. The details of public lighting duct crossing at run-in/out shall refer to Lighting Division Standard Drawings.

Best Regards,
Stanley CHOI
DE/YL(E), HyD
2762 4905



*** This e-mail message (together with any attachments) is for the designated recipient only. It may contain information that is privileged. If you are not the intended recipient, you are hereby notified that any use, retention, disclosure, copying, printing, forwarding or dissemination of the message is strictly prohibited. If you have received the message in error, please erase all copies of the message (including attachments) from your system and notify the sender immediately. *** 此電郵訊息(連同任何附件)只預給指定收件人。訊息可能包含享有特權資料。謹此通知，未經允許將此信件、圖樣或消息、保留、披露、複製、列印、轉發或發布此訊息，均受到嚴格的限制。請把訊息的所有副本(包括所有附件)從系統中刪除，並立即通知發件人。***

From: "Chi Chung Heung" <caltondespace@gmail.com>
To: deyle.nt@hyd.gov.hk
Cc: "Greg Lam" <greg@despacehk.com>, "Cheng Endy" <endydespace@gmail.com>, "W K Kwong" <wkwong@ctaconsultants.com>, "Claudia Yim" <claudiayim@ctaconsultants.com>, kelvinleung@ctaconsultants.com
Date: 10/07/2024 14:34
Subject: Planning Application No. A/YL/319 - Location of Proposed Run-in/out and the Existing Lamppost

Dear Mr. Choi,

Reference is made to the TD's comment on the captioned planning application as at 4 July 2024 (see attachment).

To address TD's comment on the location of proposed run-in/out and existing lamppost in the revised TIA, grateful if you could provide comments, if any (comment (q), extracted below in (1)). Figure 2.2 is extracted below in (2).

Should there be any queries, please do not hesitate to contact Mr. Calton Heung at 2493-3626. Thank you.


Best regards,
Calton Heung

DeSPACE (International) Limited

(1) TD's comments on the location of proposed run-in/out and existing lamppost:

(q) Figure 2.2: The location of run-in/out is close to the existing lamppost, please seek comment from Highways Department;

(2) Proposed run-in/out extracted from the revised TIA (Figure 2.2):



Virus-free www.avast.com