Proposed Rezoning From "AGR" & "GB" To "G/IC" for a Proposed "Social Welfare Facilities" (Residential Care Homes for The Elderly) (RCHE) Lot 232 RP, 232 S.A RP, 232 S.A ss. 1 to 14, 232 S.B RP, 232 S.B ss. 1 to 27, 232 S.C to 232 S.E, 233 RP, 233 S.A to 233 S.M, 237 RP, 237 S.A to 237 S.R, 239 RP, 239 S.A to 239 S.G in D.D.23, Tung Tsz, Tai Po, N.T. S12A Application for Planning Application No. Y/NE-TK/19

Response-to-Comment – WSD
(Updated 19 February 2025)

Comments		Response
1.	Comments of the Chief Engineer/Construction, Water Supplies Department as	
	follows:	
	Please advise the proposed population intake year and the additional fresh and	Proposed intake year is 2030.
	flushing water demand arising from the proposed development.	The fresh water demands = $107.1 \text{m}^3/\text{day}$ and flush water demands = $24.55 \text{m}^3/\text{day}$.