

Submission Number:

TPB/R/S/SK-HC/12- S1

就圖則作出申述

Representation Relating to Plan

參考編號

Reference Number:

241219-114731-25892

提交限期

Deadline for submission:

22/01/2025

提交日期及時間

Date and time of submission:

19/12/2024 11:47:31

「申述人」全名

Full Name of "Representer":

先生 Mr. Edmond Fong for The Hong Kong and China

Gas Company Limited

「獲授權代理人」全名

Full Name of "Authorized Agent":

與申述相關的圖則

Plan to which the representation relates:

S/SK-HC/12

申述詳情

Details of the Representation:

有關事項 Subject Matters	你支持還是反對有關事項? Are you supporting or opposing the subject matter?	理由 Reason
Item C		Since the proposed development is in the close vicinity to our High-Pressure pipeline at Hiram's Highway, the project proponent is required to conduct Quantitative Risk Assessment to evaluate the potential risk basing on the forecasted ultimate population and determine the necessary mitigation measures if required. The project proponent should consult our company in design stage and closely coordinate with our company during construction stage and provide protective measures.
Item D		Since the proposed development is in the close vicinity to our High-Pressure pipeline at Hiram's Highway, the project proponent is required to conduct Quantitative Risk Assessment to evaluate the potential risk basing on the forecasted ultimate population and determine the necessary mitigation

	<p>measures if required. The project proponent should consult our company in design stage and closely coordinate with our company during construction stage and provide protective measures.</p>
<p>Item F</p>	<p>Since the proposed development is in the close vicinity to our High-Pressure pipeline at Hiram's Highway, the project proponent is required to conduct Quantitative Risk Assessment to evaluate the potential risk basing on the forecasted ultimate population and determine the necessary mitigation measures if required. The project proponent should consult our company in design stage and closely coordinate with our company during construction stage and provide protective measures.</p>

對圖則是否有任何擬議修訂? 如有的話，請註明詳情。

Any proposed amendments to the plan? If yes, please specify the details.